


NOTE: WATERSTOPS MUST BE FULLY ENCAPSULATED WITH CONCRETE A MIN OF 3" ON BOTH SIDES

	SYSTEM	NOT TO SCALE	UNDERSLAB TRANSITION MAT SLAB TO SHOTCRETE SHORING WALL		
	E.PROFORMANCE				
	OLD REFERENCE	<small>THICKNESS OF EPRO PRODUCTS ARE ENLARGED FOR CLARITY</small>	REVISIONS	ISSUED DATE	DRAWING NO.
<small>AS A SUPPLIER OF FINISHED PRODUCTS ONLY, EPRO SERVICES, INC. DOES NOT ASSUME RESPONSIBILITY FOR ERRORS IN DESIGN, ENGINEERING OR DIMENSIONS. THE PROJECT TEAM MUST VERIFY ALL DIMENSIONS AND SUITABILITY OF DETAILS. THE PRODUCTS LISTED ARE TRADEMARKS OF EPRO SERVICES, INC.</small>			6.28.18	1.140.2	